



Underwriters  
Laboratories Inc.

## CERTIFICATE OF COMPLIANCE

Certificate Number: 031502-E60530

Report Reference : E60530- March 5, 2002

Issue Date: March 15, 2002

**MP Husky Corp.**  
**P.O Box 16749**  
**Greenville, SC 29606**

is authorized to display this Certificate under the conditions stated in the Underwriters Laboratories Inc. Certification Report(s) for the product described as follows:


**Product:** WIRE MESH CABLE TRAY SYSTEMS:PRODUCT COVERED: WIRE MESH CABLE TRAY SYSTEMS  
Tray Types Straight Sections- WB followed by 2 or 4; followed by 2,4,or 6; followed by 2,4,6,8,10,12,16,18,20,22,or 24; by 120. Splice Connector and Fitting types- SSP followed by WB2 or 90; may be followed by 2.

**Standard For Safety:** UL 568

**Additional Information:** This product is classified as to its suitability as an equipment-grounding conductor only.The Classification Marking of Underwriters Laboratories Inc. (shown below) on the product is the only method provided by UL to identify products manufactured under its Classification and Follow-Up Service. The Classification Marking for these products (shown below) includes the name and/or symbol of Underwrites Laboratories Inc.

The above-described product meets the requirements of the standards specified above as long as the conditions stated in the Certification Report(s) are satisfied. The award of this Certificate is based upon document review and on-site assessment.

The name of Underwriters Laboratories Inc., any abbreviation thereof or any symbol, shall not be used on or in connection with the product or any marketing activities unless and until specifically authorized by the certification organization as a result of establishment of appropriate service.

The UL Classification Marking includes: UL in a circle symbol  with the word "CLASSIFIED" (as shown): a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of the UL's evaluation of the product; and , the category name (product identity) as indicated in the appropriate UL Directory.